

# Vutek 3360, 2360, 5330, FabriVu, PressVu Print Head Recovery Quick Guide

## Step 1. Reverse Flush the print head

This step is required for severely clogged print heads. You may skip this step and get back to it later if you don't have a satisfactory results from the Forward Flushing methods. If you have a Reverse Flushing cap, set up your print head for reverse flushing as shown on the picture in this document. If you don't have RF Cap, use a suction method of reverse flushing as shown here. Run Syphon cycle. After it's completed, set up your print head for Forward Flushing and run it with Syphon cycle again. Use fluid # 1UV if you are cleaning a UV print head, or fluid # 1X for solvent print head, or fluid # 1W for water-based one. Temperature can be 30°-35°C. Do not exceed Max Temperature indicated on the picture. Remember that the temperature will rise due to the ultrasonic power.

## Step 2. Forward flush the print head

Set up your print head for forward flushing as shown on the picture below. If the fluid is foamy, run Syphon cycle only. For non-foamy fluids you can run Normal (F1) cycle. Start with temperature of 30°C. After the cycle has been finished, run Drain cycle (to turn on the pumps) and check nozzles. If there is improvement, repeat the cycle with a slightly higher temperature. Do not exceed Maximum Temperature or Maximum Pressure.


## Step 3. Change fluids if necessary

If you don't see improvements in the nozzles condition, move on to the next fluid (the fluid with the next number). When changing fluids, follow instructions from our videos. Set temperature to 30°C and go to Step 3.

After the print head has been recovered, fill it with the flushing solution that comes with your ink.

**Important:** do not leave recovery fluids with number higher than 1 inside the machine overnight. They will affect the pumps. Always drain the fluid and run distilled water through the machine for 1 minute, then purge the water out by allowing the machine to suck in the air and by running the AR cycle for a few seconds.

Some Vutek print heads may have clogged Piezo Modules inside, so it's practically impossible to recover them without prior cleaning of the piezo modules. We have a solution for that: Spectra Nova Piezo Module adapter and instructional video.




### Reverse Flushing Vutek head with Reverse Flushing cap

**MAX PRESSURE**  
**0.20**  
 MPa  



---

**30**  
 psi

Reverse Cap  
 Recovery Fluid  
 Tank




Maximum Temperature 45°C




1. Install Reverse Flushing cap.
2. Install 1st stage filter(s).
3. Connect RF cap tubing to output.
4. Plug the second output port.
5. Connect print head to adapter.
6. Run LPRF cycle.

### Reverse Flushing Vutek head using Suction Method

Print head  
 Recovery Fluid  
 Tank



Maximum Temperature 45°C



1. Plug both output ports.
2. Connect print head as shown.
3. Open Relief Valve (one turn).
4. Fill clean fluid up to print head.
5. Run Syphon cycle.